3. 12/20/21 200 Block N. 82nd	2. 11/20/21 Frontena (Ex. /f (Water Infra)) Temporary by-pass line leaking when pump cycles on. Tighten hose clamps to stop leak. Repair main sewer line and eliminate by-pass line.	Analysis of cause for SSO's 1. 11/17/21 200 Block of N. 82nd					12/20/2021 200 Block of N 82nd Street Ex. 7f (Water Infra.)	11/20/2021 Frontena Ex. 7f (Water Infra.)	11/17/2021 200 Block of N 82nd Street Ex. 7f (Water Infra.)	Date Location	City of Cahokia Heights - Quarterly- SSO Summary
ry submersible pump	y by-pass line leaking	rary by-pass pump clo					Unknown	100	Uknown	Discharge Volume in Gallons	
emporary submersible pump failed. Replace with new pump. New duplex lift station forthcoming.	when pump cycles on. Tighten hose clamps to	emporary by-pass pump clogged. Check by-pass pumps daily. New duplex lift station forthcoming.					Ditch to Canal #1	Absorb into soil	Ditch to Canal #1	ne Area Receiving Discharge	
ft station forthcoming.	stop leak. Repair main	lift station forthcoming.					5	1	5	Number of SSO's in Calendar Year	

City of Cahok	City of Cahokia Heights - Quarterly- SSO Summary (Sewer Backups)	y (Sewer Backups) Page 1 of 3
Date	Location	Comments
10/4/2021	800 Block Joliet Dr.	Replace by-pass pump on Mildred Ave. Make point repair to main trunk line to eliminate by-pass line.
10/7/2021	10/7/2021 1400 Block Richard Dr.	Customer problem
10/7/2021	10/7/2021 1100 Block Halloran St.	Customer Problem
10/13/2021	10/13/2021 1000 Block Upper Cahokia Rd.	Customer Problem
10/14/2021	10/14/2021 400 Block Range Lane	Main trunk line surcharged. Jet & clean main trunk line
10/15/2021	10/15/2021 1300 Block of St. Stephens Dr.	Main trunk line surcharged. Jet & clean main trunk line
10/19/2021	10/19/2021 1100 Block of St. George	Customer Problem
10/19/2021	10/19/2021 1100 Block of St. Benedict	Customer Problem
10/20/2021	10/20/2021 7000 Block of Ľake Dr.	Customer Problem
10/21/2021	10/21/2021 100 Block of St. Paul	Customer Problem
10/22/2021	10/22/2021 Westwood Dr.	Customer Problem
10/26/2021	10/26/2021 1200 Block St. Stephens Dr.	Customer Problem
10/27/2021	10/27/2021 1000 Block of St. Martin	Customer Problem
10/28/2021	700 Block of St. Nicholas	Customer Problem
11/3/2021	11/3/2021 400 Block of Godin	Replace by-pass pump. Make point repair to main trunk line to eliminate by-pass pump

Customer Problem	12/9/2021 1300 Block of Richard Dr.	12/9/2021
Customer Problem	1 700 Block of St. Martin	12/9/2021
Customer Problem	12/9/2021 500 Block of St. Barbara	12/9/2021
Customer Problem	12/6/2021 100 Block of St. Leo	12/6/2021
Customer Problem	12/2/2021 900 Block of St. 57th St.	12/2/2021
Customer Problem	12/2/2021 1100 Block of Halloran	12/2/2021
Customer Problem	12/2/2021 2000 Block of Sycamore St.	12/2/2021
Customer Problem	11/29/2021 Leonard Dr.	11/29/2021
Customer Problem	11/22/2021 Kinder Dr.	11/22/2021
Customer Problem	11/19/2021 200 Block Miskell Blvd.	11/19/2021
Customer Problem	11/17/2021 Kinder Dr.	11/17/2021
Customer Problem	11/12/2021 700 Block of St. Norbert	11/12/2021
Customer Problem	11/10/2021 700 Block of Falling Springs Rd.	11/10/2021
Customer Problem	11/9/2021 100 Block of N. 80th St.	11/9/2021
Customer Problem	11/5/2021 200 Block of Miskell Blvd.	11/5/2021
Comments	Location	Date
ry (Sewer Backups) Page 2 of 3	City of Cahokia Heights - Quarterly- SSO Summary (Sewer Backups) Page 2 of 3	City of Cahok

City of Cahok	City of Cahokia Heights - Quarterly- SSO Summary (Sewer Backups) Page 3 of 3	y (Sewer Backups) Page 3 of 3
Date	Location	Comments
12/14/2021	12/14/2021 100 Block of St. James	Customer Problem
12/16/2021	12/16/2021 400 Block of Godin St.	Remove pump & clean debris
12/20/2021	12/20/2021 300 Block N. 59th St.	Jet & clean main trunk line
12/22/2021	12/22/2021 300 Block of N. 59th Sts.	Restore electric at main disconnect
12/22/202:	12/22/202 Ex. /f (Water Infra.) Ave.	By-pass pump manhole. Make point repair to eliminate by-pass pump.
12/22/2021	12/22/2021 2900 Block Camp Jackson Rd.	Customer problem
12/23/2021	12/23/2021 1100 Block of Halloran St.	Jet & clean main trunk line